



# CERTIFICATE

## **CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° jw1959\_2018**

According to reports N° A18.05610.01, dated on 12/10/2018, we confirm that the below mentioned item was tested at Eco-scan with reference to EN ISO 354 (2013): Acoustics - Measurement of sound absorption in a reverberation room.

The items shows

'Absorption class A'

Provided that it is properly applied.

The evaluation of these properties is based on evaluation scheme specified in EN ISO 11654:1997: Acoustics - Sound absorbers for use in buildings - Rating of sound absorption.

**SAMPLE** LAUD

**Company** **LAUD bvbv**  
Rijselstraat 34  
8957 Mesen  
Belgium

Certificate No. jw1959\_2018 is valid until 11/10/2023

Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 17/10/2018

Stijn Devaere, PhD  
Director Services