



CERTIFICATE

CENTEXBEL TYPE TESTING | CERTIFICATION REPORT N° pw1956_2018

According to reports N° A18.05610.02, dated on 17/10/2018, we confirm that the below mentioned item was tested at CENTEXBEL with reference to EN-ISO 11952-2: Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test.

The items shows

'EU fire classification E'

Provided that it is properly applied.

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2007 +A1:2009 : Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

SAMPLE LAUD

Company **LAUD bvbv**
Rijselstraat 34
8957 Mesen
Belgium

Certificate No. pw1956_2018 is valid until 10/10/2023

Centexbel | Technologiepark 7 | BE 9052 Gent | Belgium, 17/10/2018

Inge De Witte, PhD
Certification Manager